



B. J. CHAUHAN & ASSOCIATES

INFRASTRUCTURE SERVICES

CIVIL | MECHANICAL | ELECTRICAL | CHEMICAL | FIRE & SAFETY

Form no. 1-A.

(Prescribed Under Rule 3-C)

CERTIFICATE OF STABILITY

Date of Report : - **09.10.2024**
Report No.: - (BJC/STAB/2399)

Date of Inspection :- **09.10.2024**

1. Name of the Factory. : - **RAMA CYLINDERS PVT. LTD.**
2. Village, Town and District in which the Factory is situated. : - **PLOT NO. 629-637,
NEW AREA K.A.S.E.Z.,
TAL. :- GANDHIDHAM,
DIST :- KUTCH**
3. Full Postal address of the Factory. : - **AS ABOVE**
4. Name of the Occupier of the Factory : - **MR. VASHU J. RAMSINGHANI**
5. Nature of manufacturing process to be carried on in the factory : - **MFG. OF HIGH PRESSURE
SEAMLESS STEEL INDUSTRIAL/
CNG GAS CYLINDERS**
6. Number of floors on which workers will be employed. : - **G.F. + F.F. + S.F.**

I certify that, I have inspected the premises the plans of which have been approved by the Dy. Development Commissioner of Kandla Special Economic Zone by his letter No. **KASEZ/ P & C/ 4/ 132/ 09/ 118 DATED :- 08/ 10 / 2009** as per drawing and examined the various parts including the foundation with special reference to the machinery, plant etc. that have been installed. I am of the opinion that all the works of engineering construction in premises is structurally sound and that its stability will not be endanger by its use as a factory for the Process / Manufacturing of **HIGH PRESSURE SEAMLESS STEEL INDUSTRIAL/ CNG GAS CYLINDERS** For which the machinery, Plant etc. installed are intended.

THIS CERTIFICATE EXPIRES ON 08.10.2029.


NIKHIL B. CHAUHAN
GUJ/DISH/CPT/A/1342/2024

Page 1/3

Annexure-I

THIS CERTIFICATE INCLUDES FOLLOWING STRUCTURES.

- MAIN PLANT BLDG.(G.F.)
- UTILITY AREA
- TOILET BLOCK
- ADMIN. BLDG. (G.F.)
- ADMIN. BLDG. (F.F.)
- ADMIN. BLDG. (S.F.)
- SECURITY CABIN 1
- SECURITY CABIN 2



NIKHIL B. CHAUHAN
GUJ/DISH/CPT/A/1342/2024

Annexure-II

By observations the structure is safe and sound. Following points may please be noted and followed for further safety of structure.

- 1) Existing position and condition of equipment shall be maintained as per approved plan. Any change of vessel increases in loading should be checked before loading.
- 2) Any change in steel structure / member / addition alteration should be checked from structural engineer.
- 3) All RCC / steel structures shall be painted and well maintained regularly, maintenance report to be maintained.
- 4) Pressure vessel / reaction vessels should be checked periodically from competent person at regular interval. Temperature and pressure should be maintained within safe limit. Otherwise increase in temperature / pressure may cause damage to steel structure.
- 5) Any abnormal settlement of any part of steel structure should be reported immediately to structural engineer.
- 6) Any vibration on steel structure if observed should be reported immediately to structural engineer
- 7) Water logging near plinth level or steel column and RCC building should be avoided to prevent settlement of columns.
- 8) All structural members shall be protected from any type of acidic materials and shall be well protected from salinity. All acidic effluent shall be properly drained to safe place by providing proper drainage. So that flooring and structural member remains unaffected by such materials
- 9) Any addition alteration and change in equipment take place revised stability certificate should be obtained.
- 10) Structural inspection report of Structure Engineer to be Submitted, Every year.
- 11) Water seepage indication found at admin office first floor & second floor staircase, suggested to repair the same.
- 12) Revision drawing is suggested to get approved as per the site & approved map.



GOVERNMENT OF GUJARAT
COMPETENT PERSON CERTIFICATE
(Prescribed under Rule 2-A)

CERTIFICATE NO. GUJ/DISH/CPT/A/1342/2024.

CERTIFICATE OF COMPETENCY ISSUED TO A PERSON OR AN INSTITUTION IN PURSUANCE TO RULE 2(A) MADE UNDER SECTION 2(ca) OF THE FACTORIES ACT, 1948.

I, P. M. Shah, Director, Industrial Safety and Health, Gujarat State in exercise of the powers conferred on me under Section 2 (ca) of the Factories Act and the rules made there under hereby recognize Shri Nikhil B. Chauhan employed in B.J. Chauhan & Associates, Plot No-66, Ward-1-B, Opp. Time College, Adipur-Kachchh-370205 to be a competent person for the purpose of carrying out tests, examinations, inspections and certifications under following section/s and the rules made there under in a factory located in Gujarat State.

Section 6 & 112 : Buildings..

The Certificate is Valid from Date :- 09/05/2024 to 08/05/2025.

This certificate is issued subject to the conditions stipulated hereunder:-

- 1) Tests, examinations and inspections shall be carried out in accordance with the provisions of the Act and the rules made there under.
- 2) Tests, examinations and inspections shall be carried out under the direct supervision of the competent person or by a person so authorized by an institution recognized to be a competent person.
- 3) The certificate of competency issued in favour of a person shall stand cancelled if the person declared competent leaves the organization mentioned in his application.
- 4) The institution recognized as a competent person shall keep the Director, Industrial Safety & Health informed of the names, designations and qualifications of the persons authorized by it to carry out tests, examinations and inspections.
- 5) The copies of certificates of examinations / tests issued by you after due examinations / tests are to be marked to the Inspector of Factories concerned within seven days in all cases where defects are noticed and repairs or alternations are suggested on its use.
- 6) The record of the work done by the competent person should be maintained in the Log Book, incorporating therein the details regarding work done, observations made, directives given etc.
- 7) Certificate No. and validity period should invariably recorded by you in all the copies of certificates of examinations / tests signed and issued by you.
- 8) Every examination / test shall conform to the relevant standard, if it is not specified in the Act or rules made there under.
- 9) Facilities and equipments to be used by you should be maintained and kept in a good and efficient working conditions at all times and calibrated from time to time.
- 10) Application for renewal of Competent Person Certificate shall be made at least two months before the date of expiry of the certificate to the Director, Industrial Safety & Health with Log book for the period of previous nine months in case of first renewal and twelve months in case of second and subsequent renewal.
- 11) Save as provided in Rule 61(9)(a) of section 31, in no case conditional certificate shall be issued.

Station : Ahmedabad.

Date : 23/5/2024



P. M. Shah

(P. M. Shah)
Director,
Industrial Safety & Health,
Gujarat State, Ahmedabad.