



GOVERNMENT OF MADHYA PRADESH  
**DIRECTORATE OF BOILERS, BHOPAL**  
(THIS CERTIFICATE MUST BE HUNG UP IN THE BOILER HOUSE)

**FORM VI**

**MADHYA PRADESH BOILER INSPECTION DEPARTMENT**  
**CERTIFICATE FOR THE USE OF A BOILER**

[Regulation 399]

No. N/276/2024

Registry No. of Boiler-MP/5714

Type of Boiler-Water Wall Furnace

Boiler Rating—237 m<sup>2</sup>

Place & Year of Manufactures-Savli-2022

Maximum Continuous Evaporation—10 T/hr

Name of Owner— Shri Saurabh Kochar, (Add. Director)  
M/s K.P. Solvex Ltd.

Situation of Boiler —Niwari, Distt. Niwari (M.P.)

Repairs—

Remarks— 1. To steam boiler in direct charge of 1<sup>st</sup> class B.A. in all shifts.

Hydraulically Tested on 01/10/2024 to 26.50 Kgs/cm<sup>2</sup>

I hereby certify that the above described boiler is permitted by me / the Director of Boilers under the provisions of Section 8 of the Boilers Act, No. V of 1923, to be worked at a maximum pressure of 17.50 Kgs/cm<sup>2</sup> for the period from 01.10.2024 to 08.09.2025.

The loading of the DSL safety valve is not to exceed 17.50 Kgs/cm<sup>2</sup> . with ferrules front-11.61 mm, & Rear- 23.45 mm thk. between lock & adjusting nut of the safety valve.

Fee Rs 5000/- paid on 31/08/2024  
Dated at Bhopal

This 03 day of October- 2024

OPEN UP BOILER FOR CLEANING  
AFTER EVERY 12 WEEKS AND  
KEEP RECORDS

Countersigned

Director of Boilers

Inspector of Boilers grade-1  
Bhopal (MP/ATEL)

Inspector of Boilers Gr 1  
Madhya Pradesh, Bhopal

[See reverse for "Conditions"]