Table of Contents

1.	Exe	cutive Summary	2			
2.	Sco	pe of Report	3			
3.	Sola	ar Sector Overview	4			
4.	Sola	ar Plant Details	6			
4.	1	Solar Irradiation and Weather Data	7			
4.	2	Annual Energy Yield Assessment	8			
4.	3	Electrical Infrastructure	9			
4.	4.4 Module Mounting Infrastructure					
5.	Оре	eration & Maintenance	9			
6.	Cor	nclusion1	0			
List	of An	nnexures	0			

1. Executive Summary

The 2.05MW_{AC} /2.7MW_{DC} rooftop Solar Power Plant at ATLI Battery, Sohna, Haryana is planned to be developed by Sunbeam Real Ventures Private Limited with a target of commissioning by June, 2025. The PPA was executed based on an initial assessment of 2.7MW_{DC}. A brief overview of the project simulation summary is also projected below:

		Project: AT	LI - Sohna		
	Ň	√ariant: ATLI_Final P	√syst report_SolarGIS		
/syst V7.4.8 E3, Simulation date: /03/25 15:56 th V7.4.8		Solo Pow	ver (India)		
		Project s	summary ———		
Geographical Site	•	Situation		Project settings	
ATLI		Latitude	28.83 °N	Albedo	0.20
India		Longitude	76.92 °E		
		Altitude	218 m		
		Time zone	UTC+5.5		
ATLI SolarGIS Monthly av	er. , period not spec S	ynthetic			
Grid-Connected S	System	Unlimited sheds	summary —		
		Neer Chedings		lleer's woods	
Sheds	ion	Mutual shadings of s	hade	User's fieeus)
Tilt	10 °	Electrical effect	icus	omminied load (grid)
Azimuth	0 °	Licencar cheet			
System information	on				
PV Array			Inverters		
Nb. of modules		4680 units	Nb. of units		17 units
Pnom total		2761 kWp	Pnom total		2050 kWac
			Pnom ratio		1.347
		Results :	summary —		
Produced Energy	4313344 kWh/year	Specific production	1562 kWh/kWp/year	Perf. Ratio PR	84.83 %

• Solar Plant Developer and Ownership (Shareholders):

- i. Sunil Gadhoke
- ii. Viraj Gadhoke

• Location and Approach Roads

ATLI Battery is located at Sohna in the state of Haryana. The geo-location of upcoming solar plant of $2MW_{AC}$ /2.7MW_{DC} at Sohna is 28.19305°N, 77.06764°E. The site proposed for the solar plant is approximately at a distance of

- 72 km from New Delhi, via NH 48
- 32 km from Gurgaon, Haryana

• Area of Rooftop Available

The area of rooftop available for developing the solar plant is approximately 17,915 m². There are 2 roofs where installation is planned. The height of the building where solar plant installation is planned is approximately 29m. The satellite image of this facility is shown hereafter where solar PV plant installation is planned.



Total Solar Power Capacity to be Developed (MW_{AC}) $2 M W_{AC}$

• Solar Power Evacuation Plan (Refer ANNEXURE 2) Solar Power transmission and evacuation of each roof is done at the 2000A feeder of the client Distribution Panel at 415V within each building. The transmission of solar power generated will be through 7Rx3.5Cx240sqmm Al/Cu cable.

2. Scope of Report

• Introduce the concept of the solar plant

A Rooftop Solar Plant is a small to medium-scale photovoltaic system (PV system) designed under C&I segment, basically for captive power consumption. They operate in grid parallel mode with the ability to export surplus power to the local electricity distribution network. It provides security of power supply and resilience through self-generation with great cost benefits, particularly when the current and the future escalated grid tariff are accounted. It also assists in reducing carbon footprints and contributes to improved environmental impacts.

• A brief description of the solar plant being planned

2.05MW_{AC} solar plant is planned at the rooftop of ATLI facility in Sohna of Haryana, India. The power generated will be consumed by the facility. The PV technology installed here is monocrystalline N-type TOPCON modules and 17 Sungrow inverters; (16)125kW and (1)50kW are used to convert the DC power generated from the PV modules to the grid.

• Purpose of the DPR

Detailed project report is a complete document for investment decision-making, approval, planning. Detailed project report is based document for planning the solar plant and implementing the solar plant. In this DPR all details, starting from Renewable energy scenario in India, Solar irradiation available at site, Type of Roof and planning of Rooftop Solar Plant installed are included.

3. Solar Sector Overview

PV Technologies

Photovoltaics (PV) is the conversion of light into electricity using semiconducting materials that exhibit the photovoltaic effect, a phenomenon studied in physics, photochemistry, and electrochemistry. A typical photovoltaic system employs solar panels, each comprising a number of solar cells, which generate electrical power. PV installations may be groundmounted, rooftop mounted or wall mounted. The mount may be fixed, or use a solar tracker to follow the sun across the sky. Solar PV has specific advantages as an energy source: once installed, its operation generates no pollution and no greenhouse gas emissions, it shows simple scalability in respect of power needs and silicon has large availability in the Earth's crust. Photovoltaic systems have long been used in specialized applications, and standalone and grid-connected PV systems have been in use since the 1990s. They were first massproduced in 2000, when German environmentalists and the Eurosolar organization got government funding for a ten thousand roof program. Advances in technology and increased manufacturing scale have in any case reduced the cost, increased the reliability, and increased the efficiency of photovoltaic installations Net metering and financial incentives, such as preferential feed-in tariffs for solar-generated electricity, have supported solar PV installations in many countries. More than 100 countries now use solar PV. The term "photovoltaic" comes from the Greek word (phos) meaning "light", and from "volt", the unit of electro-motive force, the volt, which in turn comes from the last name of the Italian physicist Alessandro Volta, inventor of the battery (electrochemical cell). The term "photovoltaic" has been in use in English since 1849. Photovoltaics are best known as a method for generating electric power by using solar cells to convert energy from the sun into a flow of electrons by the photovoltaic effect. Solar cells produce direct current electricity from sunlight which can be used to power equipment or to recharge a battery. The first practical application of photovoltaics was to power orbiting satellites and other spacecraft, but today the majority of photovoltaic modules are used for grid connected power generation. In this case, an inverter is required to convert the DC to AC. Photovoltaic power generation employs solar panels composed of a number of solar cells containing a photovoltaic material. Copper solar cables connect modules (module cable), arrays (array cable), and sub-fields. Because of the growing demand for renewable energy sources, the manufacturing of solar cells and photovoltaic arrays has advanced considerably in recent years.

Sunbeam Real Ventures Pvt Ltd/HAREDA/Rooftop Solar Plant/DPR-1

Solar photovoltaic power generation has long been seen as a clean energy technology which draws upon the planet's most plentiful and widely distributed renewable energy source – the sun. Cells require protection from the environment and is usually packaged tightly in solar panels. Photovoltaic power capacity is measured as maximum power output under standardized test conditions (STC) in "W_P" (watts peak). The actual power output at a particular point in time may be less than or greater than this standardized, or "rated", value, depending on geographical location, time of day, weather conditions, and other factors. Solar photovoltaic array capacity factors are typically under 25%, which is lower than many other industrial sources of electricity.

• Overview of Available Technology

Solar energy can be converted into electricity using the following two broad technology options:

Photovoltaics (PV) is a method of generating electrical power by converting solar radiation into direct current electricity using semiconductors that exhibit the photovoltaic effect. Photovoltaic power generation employs solar panels composed of several cells containing a photovoltaic material. Materials presently used for photovoltaic include mono-crystalline silicon, multi-crystalline silicon, amorphous silicon, cadmium telluride, and copper indium selenide/sulphide. PV uses both direct and diffuse radiation for generation of electricity. Concentrated solar power (CSP) is the system that uses lenses or mirrors to concentrate a large area of sunlight, or solar thermal energy, onto a small area. Electrical power is produced when the concentrated light is converted to heat which drives a heat engine (usually a steam turbine) connected to an electrical power generator. CSP uses only direct radiation for generating electricity. As the Solar Plants has been allocated a 20MW Solar PV, this DPR will confine itself to the description of solar photovoltaic (PV) options.

• Solar PV Technology

Photovoltaic conversion is the direct conversion of sunlight into electricity with no intervening heat engine. A PV cell consists of two or more thin layers of semiconducting material, most commonly silicon. When the silicon is exposed to light, electrical charges are generated; and this can be conducted away by metal contacts as direct current. The electrical output from a single cell is small; so multiple cells are connected and encapsulated (usually glass covered) to form a module (also called a panel). PV generation technology is commercially proven and large multi-megawatt generation plants have been operating since the 1990s. Costs associated with the technology are high, but the technology is well known and reliable. The major categories of solar photovoltaic technologies available are:

Mono-crystalline silicon cells: In these cells, the silicon has a single continuous crystal lattice structure with almost no defects or impurities. Their main advantage is high efficiency; though a complicated manufacturing process is required to produce mono-crystalline silicon, which results in higher costs than those of other technologies.

Multi-crystalline silicon cells: These cells are produced using numerous grains of monocrystalline silicon. The manufacturing process involves casting of silicon into ingots, which are subsequently cut into very thin wafers and assembled into complete cells. These are cheaper to produce because of a simpler manufacturing process.

Thin film: Extremely thin layers of photosensitive materials are deposited on a low-cost backing like glass, stainless steel or plastic. The selected materials are all strong light absorbers and only need to be about 1-micron thick, so materials costs are significantly reduced. The

Sunbeam Real Ventures Pvt Ltd/HAREDA/Rooftop Solar Plant/DPR-1

most common materials are amorphous silicon (a-Si), or the polycrystalline materials such as cadmium telluride (CdTe) and copper indium (gallium) (CIS or CIGS). Thin film cells trade-off lower efficiencies against a significantly lower cost of materials.

Concentrating PV: Concentrating the sunlight by optical devices like lenses or mirrors reduces the area of expensive cells or modules, and increases their efficiency. The most important benefit of this technology is the possibility to reach system efficiencies beyond 30%, which cannot be achieved by single junction 1-sun¹ photovoltaic technology.

1. 1-sun means testing conditions using irradiance of 1000 W/m^2



4. Solar Plant Details

• Roof Size

The area of shadow free roof available for developing the solar power plant is approximately $17,915 \text{ m}^2$.

- Total power capacity (in AC) to be located within the solar plant 2.05MW_{AC}
- External Transmission infrastructure requirements, capacity already available, augmentation required up to target destinations: (Refer ANNEXURE-2)
 Solar Power transmission and evacuation of each roof is done at the 2000A feeder of the client Distribution Panel at 415V within each building. The transmission of solar power generated will be through 7Rx3.5Cx240sqmm Al/Cu cable.
- **Solar Radiation Resource Assessment station:** The following data sensors shall be provided in the plant (in the module area) to monitor the following parameters:
 - Global Horizontal Irradiance Pyranometer
 - Collector plane Irradiance Pyranometer
 - Ambient temperature
 - Module temperature

• Drainage System:

Water based cleaning is done on the subject rooftop solar plant through a network of PVC plumbing pipes from the water tapping point to the PV module area.

• **Telecommunication infrastructures:** Communication System is planned to be installed to fetch the plant and its equipment performance data through Datalogger to monitor the plant remotely.

4.1 Solar Irradiation and Weather Data

• Average monthly GHI from the nearest met station or other reliable sources

The average monthly GHI of Sohna was taken from SolarGIS meteorological database and the following monthly values of irradiance, ambient temperature and wind speed. It experiences an annual average rainfall of 636mm. The figure below shows the monthly solar irradiation and weather data at Manesar along with the monthly generation table P50 figures as simulated in PVSyst. The simulation table also specifies the estimated PR on monthly basis.

	GlobHor	DiffHor	T_Amb	WindVel	GlobInc	DifSInc	Alb_Inc	DifS_GI
	kWh/mª	kWh/mª	°C	m/s	kWh/m²	kWh/m²	kWh/m²	ratio
January	92.0	52.8	13.10	2.3	103.6	38.69	0.139	0.000
February	122.4	56.9	16.50	2.7	136.5	35.35	0.185	0.000
March	175.8	75.4	22.20	2.1	188.7	42.00	0.267	0.000
April	193.3	88.6	28.70	2.4	199.6	47.37	0.292	0.000
May	194.5	105.3	32.50	2.6	194.5	58.78	0.295	0.000
June	163.6	100.3	33.00	2.6	162.0	60.36	0.247	0.000
July	142.9	96.5	30.10	2.3	141.8	64.56	0.217	0.000
August	152.3	92.8	28.90	2.8	154.1	58.20	0.231	0.000
September	154.6	77.9	28.10	2.3	161.8	47.82	0.234	0.000
October	147.9	73.9	25.30	2.3	161.5	45.11	0.224	0.000
November	111.1	59.6	20.20	1.8	125.6	39.64	0.169	0.000
December	97.0	52.4	15.09	2.0	111.9	36.06	0.147	0.000
Year	1747.4	932.4	24.51	2.3	1841.6	573.95	2.647	0.000

ATLI_Final PVsyst report_SolarGIS(20-03-2025) Weather data and incident energy

• Wind

Wind speed influences air temperature. In other words, at higher wind speeds, the air temperature could decrease and so does the solar cell operating temperature. That means that wind can help a solar PV system perform more efficiently to harvest the positive influence of wind on solar cell operation temperature, one will install systems at heights elevated above the surface of the roof. This allows wind to flow between the surface of the solar panels and the roof, reducing the operating temperature of the solar cells. This helps us ensure maximum module and solar PV system efficiency for your system.

Wind speed, including wind gusts, can have physical impacts on solar PV systems. For example, if a solar PV system was not installed with the correct mounting equipment (e.g. rails, attachments, fasteners, etc.) and there are high wind gusts, then the system could be damaged. If the damage is significant, the electrical operation of the system could be affected. In a worst-case scenario, the solar panels could be dislodged from the mounting equipment or the roof due to high winds. The system would lose electrical contact and be inoperable.

• Temperature

Local air temperature means the temperature of the air directly around the panels of the system. That can change how the solar PV system's voltage will function. Since solar cells – the physical material within a solar panel that converts sunlight into electricity – are under glass, they are well insulated. Thus, they have higher temperatures than the environment immediately around the panel. Temperature and voltage have an inverse relationship meaning the higher the temperature, the lower the operating voltage. Lower operating voltages cause lower module (and overall) system efficiency.

Rain and Humidity

Humidity can slow efficiency in two ways. Tiny water droplets, or water vapour, can collect on solar panels (like beads of sweat) and reflect or refract sunlight away from solar cells. This reduces the amount of sunlight hitting them and producing electricity. Consistent hot, humid weather can degrade the solar panels themselves over their lifetime. This is true for both crystalline silicon cells and thin film modules. Rain can also affect in many ways like If rainy period in year is more than generation is also reduced after rain water droplets cause same effect as above.

4.2 Annual Energy Yield Assessment

• Simulation using reputed PV software

With the Meteonorm data, PVSyst simulation at 10° tilt and azimuth of 0°S was performed to assess the annual energy yield. A degradation of 1% was considered for a duration of one year from the time of installation. The simulation was performed on the basis of $2.7MW_{DC}$ and $2.05MW_{AC}$. The simulation result obtained is as shown in the Table given below. Annual Specific yield is 1444kWh/kWp/yr.



- Orientation and tilt angle of solar PV modules: 10° tilt and azimuth of 0°S
- Capacity Utilization Factor (CUF): 16%
- Annual Degradation: 1% for the 1st year and 0.4% thereafter

4.3 Electrical Infrastructure

• Electrical Interface Point

A grid-tied solar power system produces solar electricity that is fed directly into the utility grid, hence the term grid-tied, as the system is tied, literally, to the grid. Grid-connected or utility-interactive PV systems are designed to operate in parallel with and interconnected with the electric utility grid. The primary component in grid-connected PV systems is the inverter, or power conditioning unit (PCU).

The PCU converts the DC power produced by the PV array into AC power consistent with the voltage and power quality requirements of the utility grid, and automatically stops supplying power to the grid when the utility grid is not energized. A bi-directional interface is made between the PV system AC output circuits and the electric utility network, typically at an on-site distribution panel or service entrance. This allows the AC power produced by the PV system to either supply on-site electrical loads, or to back feed the grid when the PV system output is greater than the on-site load demand.

At night and during other periods when the electrical loads are greater than the PV system output, the balance of power required by the loads is received from the electric utility.

4.4 Module Mounting Infrastructure

Customized ballast structure is planned for mounting of modules for this Rooftop Solar Project. This is to mitigate several obstructions present at the module mounting area and also avoid any damage to the waterproofing done in advance at the roof. A typical ballast structure that is proposed for this project is shown in the figure below:



5. Operation & Maintenance

The operation and maintenance of the plant will be taken care by the Asset Management Team of the project developer. Water based module cleaning and preventive maintenance as per the suggested OEM is scheduled and performed to maintain the generation guarantee and plant performance mentioned in the PPA. An annual cleaning cycles of 32-36 is undertaken with 12 monthly, 4 quarterly & 1 annual schedules of preventive maintenance. In case of any breakdowns in between these cycles, it will be attended on immediate basis.

6. Conclusion

A generation guarantee of 36,72,905kWh/yr has been mutually agreed according to the PPA.

List of Annexures

- Annexure 1: General Lay Out Plan of Solar Power Plant
- Annexure 2: Power Evacuation System Diagram
- Annexure 3: PVSyst Report
- Annexure 4: Bill of Materials









PVsyst - Simulation report

Grid-Connected System

Project: ATLI - Sohna Variant: 21-02-2025 35% overload Unlimited sheds System power: 2761 kWp ATLI - India

> Author Solo Power (India)





Project: ATLI - Sohna

Variant: ATLI_Final PVsyst report_SolarGIS

Solo Power (India)

PVsyst V7.4.8

VE3, Simulation date: 12/03/25 15:56 with V7.4.8

	Proje	ct summary —		
Geographical Site	Situation		Project setting	S
ATLI	Latitude	28.83 °N	Albedo	0.20
ndia	Longitude	76.92 °E		
	Altitude	218 m		
	Time zone	UTC+5.5		

SolarGIS Monthly aver. , period not spec. - Synthetic

		System s	ummary ——			
Grid-Connected S	system	Unlimited sheds				
PV Field Orientati	on	Near Shadings		User's needs		
Sheds		Mutual shadings of sh	eds	Unlimited load (grid)		
Tilt	10 °	Electrical effect				
Azimuth	0 °					
System information	on					
PV Array			Inverters			
Nb. of modules		4680 units	Nb. of units		17 units	
Pnom total		2761 kWp	Pnom total		2050 kWac	
			Pnom ratio		1.347	
		—— Results s	ummary ——			
Produced Energy	4313344 kWh/year	Specific production	1562 kWh/kWp/year	Perf. Ratio PR	84.83 %	
		Table of c	contents			
Proiect and results su	ummarv					2
, General parameters.	PV Array Characteristics	. Svstem losses				. 3
Main results	, -	· •				7
Loss diagram						. 8
Predef. graphs						. 9

P50 - P90 evaluation

Single-line diagram

10

11



Project: ATLI - Sohna

Variant: ATLI_Final PVsyst report_SolarGIS

Solo Power (India)

		— General para	imeters —		
Grid-Connected System	I	Unlimited sheds			
PV Field Orientation					
Orientation		Sheds configuration		Models used	
Sheds		Nb. of sheds	2 units	Transposition	Perez
Tilt	10 °	Unlimited sheds		Diffuse Perez	z, Meteonorm
Azimuth	0 °	Sizes		Circumsolar	separate
		Sheds spacing	3.02 m		
		Collector width	2.28 m		
		Ground Cov. Ratio (GCR	2) 75.4 %		
		Top inactive band	0.02 m		
		Bottom inactive band	0.02 m		
		Shading limit angle			
		Limit profile angle	27.8 °		
		Shadings electrical effe	ect		
		Cell size	15.6 cm		
		Strings in width	1 unit		
Horizon		Near Shadings		User's needs	
Free Horizon		Mutual shadings of sheds	S	Unlimited load (grid)
		Electrical effect			
Bifacial system					
Model	2D Calculati	on			
	unlimited she	ds			
Bifacial model geometry			Bifacial model definiti	ons	
Sheds spacing	3.	02 m	Ground albedo		0.30
Sheds width	2.	32 m	Bifaciality factor		80 %
Limit profile angle	28	3.6 °	Rear shading factor		5.0 %
GCR	76	6.8 %	Rear mismatch loss		10.0 %
Height above ground	0.	60 m	Shed transparent fraction	on	0.0 %

PV Array Characteristics

Array #1 - F4			
PV module		Inverter	
Manufacturer	Jinkosolar	Manufacturer	Sungrow
Model	JKM-590N-72HL4-BDV	Model	SG125CX-P2
(Original PVsyst database)		(Original PVsyst database)	
Unit Nom. Power	590 Wp	Unit Nom. Power	125 kWac
Number of PV modules	2023 units	Number of inverters	7 units
Nominal (STC)	1194 kWp	Total power	875 kWac
Modules	119 string x 17 In series	Operating voltage	180-1000 V
At operating cond. (50°C)		Pnom ratio (DC:AC)	1.36
Pmpp	1107 kWp	Power sharing within this inverter	
U mpp	674 V		
l mpp	1643 A		
PV module		Inverter	
Manufacturer	Jinkosolar	Manufacturer	Sungrow
Model	JKM-590N-72HL4-BDV	Model	SG110CX
(Original PVsyst database)		(Custom parameters definition)	
Unit Nom. Power	590 Wp	Unit Nom. Power	100 kWac
Number of PV modules	634 units	Number of inverters	3 units
Nominal (STC)	374 kWp	Total power	300 kWac



Project: ATLI - Sohna

Variant: ATLI_Final PVsyst report_SolarGIS

PVsyst V7.4.8

VE3, Simulation date: 12/03/25 15:56 with V7.4.8

Solo Power (India)

PV Array Characteristics

Number of PV modules 153 units Number of inverters 6 * MPPT 12% 0.7 unit Nominal (STC) 90.3 kWp Total power 70.5 kWac At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 83.7 kWp Max. power (=>45°C) 11.0 kWac I mpp 124 A Prom ratio (DC:AC) 1.28 Array #3 - F4 Vumber of inverters 3 * MPPT 10% 0.3 unit Nominal (STC) 37.8 kWp Total power 29.5 kWac Modules 4 string x 16 In series Operating voltage 200-1000 V Pmpp 35.0 kWp Max. power (=>45°C) 110 kWac Modules 4 string x 16 In series Operating voltage 200-1000 V Pmpp 35.0 kWp Max. power (=>45°C) 110 kWac U mpp 634 V Pnom ratio (DC:AC) 1.28 I mpp 13 string x 17 In series 1 unit Nomber of PV modules 221 units Number of inverters 1 unit Nomber of PV modules 13 string x 17 In series 1 unit At operating voltage<	Array #2 - F4			
Nominal (STC) 90.3 kWp Total power 70.5 kWac Modules 9 string x 17 In series Operating voltage 200-1000 V Pmpp 83.7 kWp Max, power (≈>45°C) 110 kWac Umpp 674 V Pnom ratio (DC:AC) 128 Array #3 - F4 Number of Inverters 3 * MPPT 10% 0.3 unit Nominal (STC) 37.8 kWp Total power 29.5 kWac Modules 4 string x 16 In series Operating voltage 200-1000 V Pmpp 35.0 kWp Total power 29.5 kWac Modules 4 string x 16 In series Operating voltage 200-1000 V Pmpp 35.0 kWp Max, power (≈45°C) 110 kWac U mpp 634 V Pnom ratio (DC:AC) 1.28 I mpp 130 kWp Total power 100 kWac Modules 13 string x 17 In series 1 unit Arcay #5 - F1A Number of Inverters 1 unit Nominal (STC) 130 kWp Total power 3 * MPPT 12% 0.3 unit Nominal (STC) 40.1 kWp	Number of PV modules	153 units	Number of inverters	6 * MPPT 12% 0.7 unit
Modules 9 string x 17 In series Operating voltage 200-1000 V At operating cond. (50°C) 63.7 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.28 I mpp 124 A	Nominal (STC)	90.3 kWp	Total power	70.5 kWac
At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 83.7 kWp Max. power (=>45°C) 110 kWac Impp 124 A 110 kWac 128 Array #3 - F4 3 * MPPT 10% 0.3 unit 1.28 Nominal (STC) 3.7.8 kWp Total power 29.5 kWac Modules 4 string x 16 in series 0perating voltage 200-1000 V Pmpp 35.0 kWp Total power 29.5 kWac Modules 4 string x 16 in series 0perating voltage 200-1000 V Pmpp 35.0 kWp Max. power (=>45°C) 110 kWac U mpp 634 V Pnom ratio (DC:AC) 1.28 I mpp 55 A 100 kWac 100 kWac Mominal (STC) 130 kWp Total power 100 kWac Modules 13 string x 17 in series 110 kWac 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.30 Pmp 179 A Power sharing within this inverter 4 toperating cond. (50°C) 100 kWac Modules 4 strin	Modules	9 string x 17 In series		
Pmpp 83.7 W/p Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.28 Impp 124 A Imp 124 A Array #3 - F4 Number of Inverters 3 * MPPT 10% 0.3 unit Nominal (STC) 37.8 kWp Total power 29.5 kWac At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 35.0 kWp Max. power (=>45°C) 110 kWac I mpp 63.4 V Pnom ratio (DC:AC) 1.28 I mpp 63.4 V Pnom ratio (DC:AC) 1.28 I mpp 55 A Imp 1.28 Array #5 - F1A Ump 1.28 Imp Nominal (STC) 130 kWp Total power 100 kWac Modules 13 string x 17 In series 1 unit Number of Inverters 1 unit Number of PW modules 68 units Number of Inverters 3 * MPPT 12% 0.3 unit I npp 179 A Power sharing within this inverter Array #5 - F1A Number of PW modules 68 units Number	At operating cond. (50°C)		Operating voltage	200-1000 V
U mpp 674 ∨ Pnom ratio (DC:AC) 1.28 I mpp 124 A A Array #3 - F4 Number of inverters 3 * MPPT 10% 0.3 unit Nominal (STC) 37.8 kWp Total power 29.5 kWac Modules 4 string x 16 In series 4 4 At operating cond. (50°C) Operating voltage 200-1000 ∨ Pmpp 35.0 kWp Max. power (=>45°C) 110 kWac U mpp 634 ∨ Pnom ratio (DC:AC) 1.28 I mpp 55 A Number of inverters 1 unit Number of PV modules 221 units Number of inverters 1 unit Nominal (STC) 130 kWp Total power 100 kWac Modules 13 string x 17 In series 1 unit Now At operating cond. (50°C) Operating voltage 200-1000 ∨ Pmpp 121 kWp Max. power (=>45°C) 110 kWac I mpp 674 ∨ Pnom ratio (DC:AC) 1.30 kWac I mpp 68 units Number of inverters 3 * MPPT 12% 0.3 unit <td< td=""><td>Pmpp</td><td>83.7 kWp</td><td>Max. power (=>45°C)</td><td>110 kWac</td></td<>	Pmpp	83.7 kWp	Max. power (=>45°C)	110 kWac
Impp 124 A Array #3 - F4 Number of Ivverters 3 * MPPT 10% 0.3 unit Nominal (STC) 37.8 kWp Total power 3 * MPPT 10% 0.3 unit Modules 4 string x 16 In series Operating voltage 200-1000 V Pmpp 35.0 kWp Max. power (≈ 45*°C) 110 kWace Impp 634 V Pnom ratio (DC-AC) 1.28 Impp 55 A 100 kWace 100 kWace Array #5 - F1A Number of inverters 1 unit Nominal (STC) 130 kWp Total power 100 kWace Modules 13 string x 17 In series 1 unit Number of inverters 1 unit Modules 13 string x 17 In series Operating voltage 200-1000 V Pmpp 121 kWp Max. power (≈ 45*°C) 1.10 kWace Impp 179 A Power sharing within this inverter Array #6 - F1A Number of PV modules 68 units Number of inverters 3 * MPPT 12% 0.3 unit Nominal (STC) 40.1 kWp Total power 3 * MPYT 12% 0.3 unit Nominal (STC)	U mpp	674 V	Pnom ratio (DC:AC)	1.28
Aray #3 - F4Number of FV modules64 unitsNumber of inverters3 * MPPT 10% 0.3 unitNominal (STC)37.8 kWpTotal power29.5 kWacModules4 string × 16 In seriesOperating voltage200-1000 VAt operating cond. (50°C)Operating voltage200-1000 VPmpp35.0 kWpMax. power (\approx >45°C)110 kWacImpp55 ANomber of Inverters1 unitArray #5 - F1ANumber of inverters1 unitNumber of FV modules221 unitsNumber of inverters1 unitNominal (STC)130 kWpTotal power100 kWacModules13 string × 17 In seriesOperating voltage200-1000 VAt operating cond. (50°C)Operating voltage200-1000 VPmpp121 kWpMax. power (\approx >45°C)110 kWacUmpp674 VProm ratio (DC:AC)1.30Impp179 APower sharing within this inverterArray #6 - F1ANumber of inverters3 * MPPT 12% 0.3 unitNominal (STC)40.1 kWpTotal power3 * MPPT 12% 0.3 unitNominal (STC)40.1 kWpTotal power3.4 rkWacModules4 string × 17 In seriesOperating voltage200-1000 VArray #7 - F1ANumber of inverters3 * MPPT 12% 0.3 unitNominal (STC)674 VPomor ratio (DC:AC)1.16 kWacImpp37.2 kWpMax. power (\approx 45°C)110 kWacModules4 string × 17 In seriesAt operating voltage200-1000 VArray #7 - F1A	l mpp	124 A		
Number of PV modules 64 units Number of inverters 3 * MPPT 10% 0.3 unit Nominal (STC) 37.8 kWp Total power 29.5 kWac Modules 4 string x 16 In series Coperating voltage 200-1000 V Pmpp 35.0 kWp Max. power (=>45°C) 110 kWac U mpp 634 V Pnom ratio (DC.AC) 1.28 Impp 634 V Pnom ratio (DC.AC) 1.28 Number of PV modules 221 units Number of inverters 1 unit Nominal (STC) 130 kWp Total power 100 kWac Modules 13 string x 17 In series 100 kWac 100 kWac A toperating cond. (50°C) Operating voltage 200-1000 V Pmpp 121 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC.AC) 1.30 I mpp 179 A Power sharing within this inverter 3 * MPPT 12% 0.3 unit Nominal (STC) 40.1 kWp Total power 3 * MPPT 12% 0.3 unit Nominal (STC) 40.1 kWp Total power 3 * MPPT 12% 0.3 unit <	Array #3 - F4			
Nominal (STC) 37.8 kWp Total power 29.5 kWac Modules 4 string x 16 in series 200-1000 V Pmpp 35.0 kWp Max. power (=>45°C) 110 kWac U mpp 634 V Pnom ratio (DC:AC) 1.28 I mp 55 A 1 1 Array #5 - F1A Total power 100 kWac Number of PV modules 221 units Number of inverters 1 unit Nominal (STC) 130 kWp Total power 100 kWac Modules 13 string x 17 In series 110 kWac 100 kWac Momper of PV modules 13 string x 17 In series 200-1000 V 110 kWac Pmpp 179 A Power sharing within this inverter 1.30 I mpp 674 V Pnom ratio (DC:AC) 1.30 I mpp 179 A Power sharing within this inverter 3* MPPT 12% 0.3 unit Nominal (STC) 40.1 kWp Total power 34.7 kWac Modules 4 string x 17 In series 200-1000 V Pmpp 37.2 kWp Max. power (=>45°C) 110 kW	Number of PV modules	64 units	Number of inverters	3 * MPPT 10% 0.3 unit
Modules 4 string x 16 In series Operating voltage 200-1000 V Pmpp 35.0 kWp Max. power (=>45°C) 110 kWac Impp 634 V Pnom ratio (DC:AC) 1.28 Impp 55 A Imp 100 kWac Array #5 - F1A Number of Inverters 1 unit Number of PV modules 221 units Number of inverters 1 unit Nominal (STC) 130 kWp Total power 100 kWac At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 13 string x 17 In series Operating voltage 200-1000 V At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 121 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.30 Imp 179 A Power sharing within this inverter At operating cond. (50°C) 100 kWac Modules 4 string x 17 In series At operating voltage 200-1000 V Pmp Pmpp 37.2 kWp Max. power (=>45°C) 110 kWac Umpp	Nominal (STC)	37.8 kWp	Total power	29.5 kWac
At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 35.0 kWp Max. power (=>45°C) 110 kWac U mpp 634 V Pnom ratio (DC.AC) 1.28 Impp 55 A Pnom ratio (DC.AC) 1.28 Array #5 - F1A Number of inverters 1 unit Number of PV modules 221 units Number of inverters 1 unit Nominal (STC) 130 kWp Total power 100 kWac Modules 13 string x 17 In series Operating voltage 200-1000 V Pmpp 121 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.30 I mpp 179 A Power sharing within this inverter Array #6 - F1A Impp 3 * MPPT 12% 0.3 unit Nomber of PV modules 68 units Number of inverters 3 * MPPT 12% 0.3 unit Nominal (STC) 40.1 kWp Total power 3 * 0.47 kWac Modules 4 string x 17 In series At operating voltage 200-1000 V Pmpp 37.2 kWp Max. power (=	Modules	4 string x 16 In series		
Pmpp 35.0 kWp Max. power (=>45°C) 110 kWac U mpp 634 V Pnom ratio (DC:AC) 1.28 I mpp 55 A Array #5 - F1A Number of PV modules 221 units Number of inverters 1 unit Nominal (STC) 130 kWp Total power 100 kWac Modules 13 string x 17 In series Operating voltage 200-1000 V Pmpp 121 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.30 I mpp 179 A Power sharing within this inverter	At operating cond. (50°C)	-	Operating voltage	200-1000 V
U mpp 634 V Pnom ratio (DC:AC) 1.28 I mpp 55 A 1000000000000000000000000000000000000	Pmpp	35.0 kWp	Max. power (=>45°C)	110 kWac
Impp 55 A Array #5 - F1A Number of PV modules 221 units Number of inverters 1 unit Nominal (STC) 130 kWp Total power 100 kWac Modules 13 string x 17 In series Actoperating voltage 200-1000 V Pmpp 121 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 130 I mpp 179 A Power sharing within this inverter Array #6 - F1A Total power 3 * MPPT 12% 0.3 unit Number of PV modules 68 units Number of inverters 3 * MPPT 12% 0.3 unit Nominal (STC) 40.1 kWp Total power 34.7 kWac Modules 4 string x 17 In series At operating cond. (50°C) 110 kWac Pmpp 37.2 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.16 I mpp 55 A 110 kWac 110 kWac At operating cond. (50°C) 75.5 kWp Total power 6 * MPPT 11% 0.7 unit Nominal (STC)	Umpp	634 V	Pnom ratio (DC:AC)	1.28
Array #5 - F1A Number of PV modules 221 units Number of inverters 1 unit Nominal (STC) 130 kWp Total power 100 kWac Modules 13 string x 17 In series Operating voltage 200-1000 V Pmpp 121 kWp Max. power (=>45°C) 110 kWac Umpp 674 V Pnom ratio (DC:AC) 1.30 Impp 179 A Power sharing within this inverter Array #6 - F1A At operating cond. (50°C) 3.4.7 kWac Number of PV modules 68 units Number of inverters 3 * MPPT 12% 0.3 unit Nominal (STC) 40.1 kWp Total power 34.7 kWac Modules 4 string x 17 In series Operating voltage 200-1000 V Pmpp 37.2 kWp Max. power (=>45°C) 110 kWac Umpp 674 V Pnom ratio (DC:AC) 1.16 Impp 55 A Impp 1.6 Array #7 - F1A Impp 55 A Impp At operating cond. (50°C) 75.5 kWp Total power 6.5.3 kWac M	l mpp	55 A		
Number of PV modules 221 units Number of inverters 1 unit Nominal (STC) 130 kWp Total power 100 kWac Modules 13 string x 17 In series Operating voltage 200-1000 V At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 121 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.30 I mpp 179 A Power sharing within this inverter Array #6 - F1A Number of PV modules 68 units Number of inverters 3 * MPPT 12% 0.3 unit Nominal (STC) 40.1 kWp Total power 34.7 kWac Modules 4 string x 17 In series At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 37.2 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.16 Impp 55 A Array #7 - F1A At operating cond. (50°C) 100 kWac Number of PV modules 128 units Number of inverters 6 * MPPT 11% 0.7 unit Nominal (STC)<	Array #5 - F1A			
Nominal (STC) 130 kWp Total power 100 kWac Modules 13 string x 17 In series 00 kWac At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 121 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.30 I mpp 179 A Power sharing within this inverter Array #6 - F1A	Number of PV modules	221 units	Number of inverters	1 unit
Modules 13 string x 17 In series Operating voltage 200-1000 V At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 121 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.30 I mpp 179 A Power sharing within this inverter Array #6 - F1A Number of PV modules 68 units Number of inverters 3 * MPPT 12% 0.3 unit Nominal (STC) 40.1 kWp Total power 34.7 kWac Modules 4 string x 17 In series Operating voltage 200-1000 V At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 37.2 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.16 I mpp 55 A A Array #7 - F1A Number of PV modules 128 units Number of inverters 6 * MPPT 11% 0.7 unit Nominal (STC) 75.5 kWp Total power 65.3 kWac Modules 8 string x 16 In series A A A	Nominal (STC)	130 kWp	Total power	100 kWac
At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 121 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.30 I mpp 179 A Power sharing within this inverter Array #6 - F1A Number of PV modules 68 units Number of inverters 3 * MPPT 12% 0.3 unit Nominal (STC) 40.1 kWp Total power 34.7 kWac Modules 4 string x 17 ln series At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 37.2 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.16 Impp 55 A Array #7 - F1A Number of PV modules 128 units Number of inverters 6 * MPPT 11% 0.7 unit Nominal (STC) 75.5 kWp Total power 6 * 3.3 kWac Modules 8 string x 16 ln series At operating cond. (50°C)	Modules	13 string x 17 In series		
Properting control (cond) 121 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.30 I mpp 179 A Power sharing within this inverter Array #6 - F1A Number of PV modules 68 units Number of inverters 3 * MPPT 12% 0.3 unit Nominal (STC) 40.1 kWp Total power 34.7 kWac Modules 4 string x 17 In series Atoperating cond. (50°C) Operating voltage 200-1000 V Pmpp 37.2 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.16 I mpp 55 A 110 kWac V Number of inverters 6 * MPPT 11% 0.7 unit Number of PV modules 128 units Number of inverters 6 * MPPT 11% 0.7 unit Nominal (STC) 75.5 kWp Total power 65.3 kWac Modules 8 string x 16 In series At operating cond. (50°C) Operating voltage 200-1000 V P	At operating cond. (50°C)		Operating voltage	200-1000 V
U mpp 179 Å 179 Å Pnom ratio (DC:AC) 1.30 I mpp 179 Å Power sharing within this inverter Array #6 - F1A Number of PV modules 68 units Number of inverters 3 * MPPT 12% 0.3 unit Nominal (STC) 40.1 kWp Total power 34.7 kWac Modules 4 string x 17 In series At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 37.2 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.16 I mpp 55 Å Array #7 - F1A Number of PV modules 128 units Number of inverters 6 * MPPT 11% 0.7 unit Nominal (STC) 75.5 kWp Total power 65.3 kWac Modules 8 string x 16 In series At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 10.0 kWp Max. power (=>45°C) 110 kWac I mpp 55 A 100 kWp Max. power (=>45°C) 110 kWac I mpp 10.0 kWp Max. power (=>45°C) 110 kWac I mpp 10.0 kWp Max. power (=>45°C) 110 kWac	Pmpp	121 kWp	Max power (=>45°C)	110 kWac
Imp179 APower sharing within this inverterArray #6 - F1APower sharing within this inverterNumber of PV modules68 unitsNumber of inverters3 * MPPT 12% 0.3 unitNominal (STC)40.1 kWpTotal power34.7 kWacModules4 string x 17 In seriesAt operating cond. (50°C)Operating voltage200-1000 VPmpp37.2 kWpMax. power (=>45°C)110 kWacU mpp674 VPnom ratio (DC:AC)1.16I mpp55 AArray #7 - F1ANumber of inverters6 * MPPT 11% 0.7 unitNominal (STC)75.5 kWpTotal power65.3 kWacModules8 string x 16 In seriesAt operating cond. (50°C)Operating voltage200-1000 VPmpp70.0 kWpMax. power (=>45°C)110 kWacU mpp634 VPnom ratio (DC:AC)1.16I mpp110 A110 kWac		674 V	Pnom ratio (DC:AC)	1.30
Array #6 - F1ANumber of PV modules68 unitsNumber of inverters3 * MPPT 12% 0.3 unitNominal (STC)40.1 kWpTotal power34.7 kWacModules4 string x 17 ln seriesAt operating cond. (50°C)Operating voltage200-1000 VPmpp37.2 kWpMax. power (=>45°C)110 kWacU mpp674 VPnom ratio (DC:AC)1.16I mpp55 AArray #7 - F1ANumber of PV modules128 unitsNumber of inverters6 * MPPT 11% 0.7 unitNominal (STC)75.5 kWpTotal power65.3 kWacModules8 string x 16 ln seriesAt operating cond. (50°C)Operating voltage200-1000 VPmpp70.0 kWpMax. power (=>45°C)110 kWacU mpp634 VPnom ratio (DC:AC)1.16I mpp110 A110 kWac		179 A	Power sharing within this i	nverter
Array #6 - F1A Number of PV modules 68 units Number of inverters 3 * MPPT 12% 0.3 unit Nominal (STC) 40.1 kWp Total power 34.7 kWac Modules 4 string x 17 In series 200-1000 V At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 37.2 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.16 I mpp 55 A	· · · · · · · · · · · · · · · · · · ·		i ener enannig mann ane n	
Nominal (STC)40.1 kWpTotal power34.7 kWacModules4 string x 17 ln seriesAt operating cond. (50°C)Operating voltage200-1000 VPmpp37.2 kWpMax. power (=>45°C)110 kWacU mpp674 VPnom ratio (DC:AC)1.16I mpp55 AArray #7 - F1ANumber of PV modules128 unitsNumber of inverters6 * MPPT 11% 0.7 unitNominal (STC)75.5 kWpTotal power65.3 kWacModules8 string x 16 ln seriesOperating voltage200-1000 VAt operating cond. (50°C)0perating voltage200-1000 VPmpp70.0 kWpMax. power (=>45°C)110 kWacU mpp634 VPnom ratio (DC:AC)1.16I mpp110 A110 A110 A	Array #6 - F1A	68 unite	Number of inverters	3 * MPPT 12% 0.3 unit
Modules 4 string x 17 ln series At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 37.2 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.16 I mpp 55 A Array #7 - F1A Number of PV modules 128 units Number of inverters 6 * MPPT 11% 0.7 unit Nominal (STC) 75.5 kWp Total power 65.3 kWac Modules 8 string x 16 ln series At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 70.0 kWp Total power 65.3 kWac Modules 8 string x 16 ln series At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 70.0 kWp Max. power (=>45°C) 110 kWac U mpp 634 V Pnom ratio (DC:AC) 1.16 I mpp 110 A 110 A	Nominal (STC)		Total power	34.7 kWac
At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 37.2 kWp Max. power (=>45°C) 110 kWac U mpp 674 V Pnom ratio (DC:AC) 1.16 I mpp 55 A	Modules	A string x 17 In spring		
At operating cond. (50 °C)37.2 kWpMax. power (=>45°C)110 kWacPmpp37.2 kWpMax. power (=>45°C)1.10 kWacU mpp674 VPnom ratio (DC:AC)1.16I mpp55 AArray #7 - F1ANumber of PV modules128 unitsNumber of inverters6 * MPPT 11% 0.7 unitNominal (STC)75.5 kWpTotal power65.3 kWacModules8 string x 16 ln series200-1000 VPmpp70.0 kWpMax. power (=>45°C)110 kWacU mpp634 VPnom ratio (DC:AC)1.16I mpp110 A	At operating cond (50°C)	4 SUTING A 17 TH SELLES	Operating voltage	200, 1000 V
Impp37.2 kWpMax. power (=>45 C)The kWacU mpp674 VPnom ratio (DC:AC)1.16I mpp55 AAArray #7 - F1ANumber of PV modules128 unitsNumber of inverters6 * MPPT 11% 0.7 unitNominal (STC)75.5 kWpTotal power65.3 kWacModules8 string x 16 ln seriesAt operating cond. (50°C)Operating voltage200-1000 VPmpp70.0 kWpMax. power (=>45°C)110 kWacU mpp634 VPnom ratio (DC:AC)1.16I mpp110 A110 A110 kWac	Dmpn	37.2 k\Mp		
O httppO / 4 VPhot http:// (DC.AC)1.16I mpp55 AArray #7 - F1ANumber of PV modules128 unitsNumber of inverters6 * MPPT 11% 0.7 unitNominal (STC)75.5 kWpTotal power65.3 kWacModules8 string x 16 In series6 * MPPT 11% 0.7 unitAt operating cond. (50°C)Operating voltage200-1000 VPmpp70.0 kWpMax. power (=>45°C)110 kWacU mpp634 VPnom ratio (DC:AC)1.16I mpp110 A110 A110 kWac	і прр Пітрр	674 V	$\frac{1}{1}$	1 16
Array #7 - F1ANumber of PV modules128 unitsNumber of inverters6 * MPPT 11% 0.7 unitNominal (STC)75.5 kWpTotal power65.3 kWacModules8 string x 16 ln series6 * MPPT 11% 0.7 unitAt operating cond. (50°C)Operating voltage200-1000 VPmpp70.0 kWpMax. power (=>45°C)110 kWacU mpp634 VPnom ratio (DC:AC)1.16I mpp110 A110 A110 kWac		55 A	FIIOIII TAILO (DC.AC)	1.10
Array #7 - F1ANumber of PV modules128 unitsNumber of inverters6 * MPPT 11% 0.7 unitNominal (STC)75.5 kWpTotal power65.3 kWacModules8 string x 16 ln series6 * MPPT 11% 0.7 unitAt operating cond. (50°C)Operating voltage200-1000 VPmpp70.0 kWpMax. power (=>45°C)110 kWacU mpp634 VPnom ratio (DC:AC)1.16I mpp110 A110 A110 kWac	і шрр	A CC		
Number of PV modules128 unitsNumber of inverters6 * MPP1 11% 0.7 unitNominal (STC)75.5 kWpTotal power65.3 kWacModules8 string x 16 ln series0perating voltage200-1000 VAt operating cond. (50°C)70.0 kWpMax. power (=>45°C)110 kWacU mpp634 VPnom ratio (DC:AC)1.16I mpp110 A110 A	Array #7 - F1A	400	Niumahan of Successful	
Nominal (STC) 75.5 kWp Total power 65.3 kWac Modules 8 string x 16 ln series 200-1000 V At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 70.0 kWp Max. power (=>45°C) 110 kWac U mpp 634 V Pnom ratio (DC:AC) 1.16 I mpp 110 A	Number of PV modules			
Modules 8 string x 16 In series At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 70.0 kWp Max. power (=>45°C) 110 kWac U mpp 634 V Pnom ratio (DC:AC) 1.16 I mpp 110 A X X X	Nominal (STC)	75.5 kWp	l otal power	65.3 kWac
At operating cond. (50°C) Operating voltage 200-1000 V Pmpp 70.0 kWp Max. power (=>45°C) 110 kWac U mpp 634 V Pnom ratio (DC:AC) 1.16 I mpp 110 A 110 A 110 kWac	Modules	8 string x 16 In series		
Pmpp 70.0 kWp Max. power (=>45°C) 110 kWac U mpp 634 V Pnom ratio (DC:AC) 1.16 I mpp 110 A 110 A 110 A	At operating cond. (50°C)		Operating voltage	200-1000 V
U mpp 634 V Pnom ratio (DC:AC) 1.16 I mpp 110 A 1 1	Pmpp	70.0 kWp	Max. power (=>45°C)	110 kWac
I mpp 110 A	U mpp	634 V	Pnom ratio (DC:AC)	1.16
	l mpp	110 A		



Project: ATLI - Sohna

Variant: ATLI_Final PVsyst report_SolarGIS

Solo Power (India)

PV Array Characteristics

Array #4 - F1A			
PV module		Inverter	
Manufacturer	Jinkosolar	Manufacturer	Sungrow
Model	JKM-590N-72HL4-BDV	Model	SG125CX-P2
(Original PVsyst database)		(Custom parameters definition)	
Jnit Nom. Power	590 Wp	Unit Nom. Power	125 kWac
lumber of PV modules	2023 units	Number of inverters	7 units
lominal (STC)	1194 kWp	Total power	875 kWac
lodules	119 string x 17 In series	Operating voltage	180-1000 V
t operating cond. (50°C)		Pnom ratio (DC:AC)	1.36
mpp	1107 kWp	Power sharing within this inverter	
mpp	674 V		
трр	1643 A		
otal PV power		Total inverter power	
ominal (STC)	2761 kWp	Total power	2050 kWac
otal	4680 modules	Number of inverters	17 units
lodule area	12090 m²	Pnom ratio	1.35
		Power sharing defined	

Array losses

Array Soiling Losses		Thermal Loss fac	tor	LID - Light Induced Degradation	
Loss Fraction	3.0 %	Module temperature	according to irradiance	Loss Fraction	1.0 %
		Uc (const)	29.0 W/m²K		
		Uv (wind)	0.0 W/m²K/m/s		
Module Quality Loss		Module mismatch	n losses		
Loss Fraction	0.0 %	Loss Fraction	2.0 % at MPP		

IAM loss factor

Incidence effect (IAM): Fresnel, AR coating, n(glass)=1.526, n(AR)=1.290

0°	30°	50°	60°	70°	75°	80°	85°	90°
1.000	0.999	0.987	0.962	0.892	0.816	0.681	0.440	0.000

DC wiring losses								
Global wiring resistance	3.2 mΩ							
Loss Fraction	1.7 % at STC							
Array #1 - F4			Array #2 - F4					
Global array res.		8.9 mΩ	Global array res.	88 mΩ				
Loss Fraction		2.0 % at STC	Loss Fraction	1.5 % at STC				
Array #3 - F4			Array #4 - F1A					
Global array res.		187 mΩ	Global array res.	6.7 mΩ				
Loss Fraction		1.5 % at STC	Loss Fraction	1.5 % at STC				
Array #5 - F1A			Array #6 - F1A					
Global array res.		61 mΩ	Global array res.	199 mΩ				
Loss Fraction		1.5 % at STC	Loss Fraction	1.5 % at STC				
Array #7 - F1A								
Global array res.		94 mΩ						
Loss Fraction		1.5 % at STC						

	Project:	: ATLI - Sohna	
	Variant: ATLI_Fin	al PVsyst report_SolarGIS	
PVsyst V7.4.8 VE3, Simulation date: 12/03/25 15:56 with V7.4.8	Solo	Power (India)	
	Sys	tem losses ———	
Unavailability of the s	ystem		
Time fraction	0.8 %		
	3.0 days,		
	3 periods		
	AC w	viring losses ———	
Inv. output line up to i	iniection point		
Inverter voltage	400 Vac tri		
Loss Fraction	0.86 % at STC		
Inverter: SG125CX-P2		Inverter: SG110CX	
Wire section (14 Inv.)	Copper 14 x 3 x 120 mm ²	Wire section (3 Inv.)	Copper 3 x 3 x 70 mm ²
Average wires length	61 m	Average wires length	0 m



Project: ATLI - Sohna

Variant: ATLI_Final PVsyst report_SolarGIS

PVsyst V7.4.8 VE3, Simulation date: 12/03/25 15:56 with V7.4.8

Solo Power (India)

Main results

System Production

Produced Energy (P50) 4313344 kWh/year Produced Energy (P75) 4142271 kWh/year Produced Energy (P90) 3987957 kWh/year Specific production (P50) Specific production (P75) Specific production (P90)

1562 kWh/kWp/year Perf. Ratio PR 1500 kWh/kWp/year 1444 kWh/kWp/year 84.83 %

Normalized productions (per installed kWp)





GlobHor DiffHor T_Amb GlobInc GlobEff EArray E_Grid PR kWh/m² kWh/m² °C kWh/m² kWh/m² kWh kWh ratio 52.8 January 92.0 13.10 103.6 97.0 257275 241685 0.845 February 56.9 136.5 128.9 339904 331832 0.880 122.4 16.50 March 175.8 75.4 22.20 188.7 178.7 455405 444488 0.853 April 193.3 88.6 28.70 199.6 189.3 470586 459268 0.833 460622 May 105.3 194.5 0.838 194.5 32.50 184.0 450062 June 162.0 387192 163.6 100.3 33.00 152.9 360816 0.807 July 142.9 96.5 30.10 141.8 133.4 341584 327864 0.837 0.858 August 152.3 92.8 28.90 154.1 145.4 373709 365110 September 28.10 0.848 154.6 77 9 161.8 152.9 387939 378871 October 147.9 73.9 25.30 161.5 152.8 392641 383498 0.860 November 59.6 20.20 125.6 118.0 307689 300693 0.867 111.1 December 97.0 52.4 15.09 111.9 104.8 275484 269156 0.871 932.4 4450030 Year 1747.4 24.51 1841.6 1738.0 4313344 0.848

Legends

GlobHor	Global horizontal irradiation	EArray	Effective energy at the output of the array
DiffHor	Horizontal diffuse irradiation	E_Grid	Energy injected into grid
T_Amb	Ambient Temperature	PR	Performance Ratio
GlobInc	Global incident in coll. plane		
GlobEff	Effective Global, corr. for IAM and shadings		

Balances and main results

12/03/25



Project: ATLI - Sohna

Variant: ATLI_Final PVsyst report_SolarGIS

Solo Power (India)





Project: ATLI - Sohna

Variant: ATLI_Final PVsyst report_SolarGIS

Solo Power (India)





with V7.4.8

Project: ATLI - Sohna

Variant: ATLI_Final PVsyst report_SolarGIS

PVsyst V7.4.8 VE3, Simulation date: 12/03/25 15:56

Solo Power (India)

Weathe	er data		
Source	SolarGIS Monthly aver. , period not spec.		
Kind	Monthly averages		
Synthetic	c - Multi-year average		
Year-to-year variability(Variance) 5		.6 %	
Specifie	d Deviation		
Climate	change	0	.0 %

Global variability (weather data + system) Variability (Quadratic sum) 5.9 %

P50 - P90 evaluation

Simulation and parameters uncertainties		
PV module modelling/parameters	1.0 %	
Inverter efficiency uncertainty	0.5 %	
Soiling and mismatch uncertainties	1.0 %	
Degradation uncertainty	1.0 %	

Annual production probability

254 MWh
4313 MWh
4142 MWh
3988 MWh



Probability distribution



BILL OF MATERIAL					
	ENERGT	Site Name · ATLL Sohna			
		2761.2 kWp Solar Photovoltaic Power P	lant		
Deve	eloper: - Sunbeam Real	Venture Pvt. Ltd	25-	04-2025	
			Prepared By · A	sifKhan	
Douv	an Dunchagan - ATLL C	ahna	Checked Dy : 7	Chabman	
POwe	er Purchaser . ATLI, 5		Checked by . S		
Sr. No.	Components on Supply	Technical Specification	MAKE	UOM	Quantity
1	Solar PV Module	590 Wp Monocrystalline with 1400 mm module cable	Jinko	NOS.	4680
2	Solar Inverter with canopy	50 kW CX-P2	Sungrow	NOS.	16
	ACDB-1 with stand & canopy	8-in(1R-3.5C-240 Sq.mm AL with 4P,250A MCCB) , 1-out (7R- 3.5C-240 Sq.mm AL)) with 2000A 4P MCCB with EFR , 4P AL BUSBAR, IP6X at 415V	Standard	NOS.	1
3	ACDB-2 with stand & canopy	9-in(8-in(1R-3.5C-240 Sq.mm AL with 4P,250A MCCB)& 1- in(1R-3.5C-50 Sq.mm AL with 4P,125A MCCB)), 1-out (7R- 3.5C-240 Sq.mm AL)) with 2000A 4P MCCB with EFR , 4P AL BUSBAR, IP6X at 415V	Standard	NOS.	1
4	Copper Junction Box with copper bus bar	7R-in(3.5C-240 Sq.mm AL) , 5R-out (3.5C-240 Sq.mm Cu)	Standard	NOS.	2
5	MFM	CT Ratio 2000/5A, 0.5 Class	Secure	Set	2
		Al-3.5C-XLPE(1.1 kV), 50 Sq.mm. , Multistrand, Armoured	Seichem/Polycab	Meter	7
6	AC Cable	Al-3.5C-XLPE(1.1 kV), 240 Sq.mm. , Multistrand, Armoured	Seichem/Polycab	Meter	1500
7	DC Cable	Cu-3.5C-XLPE(1.1 kV), 240 Sq.mm. , Multistrand, Armoured DC Solar cable 6 Sq.mm (Single core,XLPO-UV stabilized) as per TUV 2Pfr 1169/08 2007 CF	Seichem/Polycab Seichem/Polycab	Meter Meter	80 103250
		4 Sq. mm 1C Cu	Seichem/Polycab	Meter	1720
8	Earthing Cable	10 Sq. mm 1C Cu	Seichem/Polycab	Meter	5
, T	Latting casts	50 Sq. mm 1C Cu	Seichem/Polycab	Meter	80
		1C 50 Sq.mm Cu Down Conductor	Seichem/Polycab	Meter	500
9	Earthing Strip	50 x 6 mm GI FLAT	Standard	Meter	660
10	Earthing Electrode	17.2 mm dia and 3 meter long CU Coated(250 Microns) Steel Rod Earthing Electrode with 22.5 kg Earthing Backfill Compound Chemical, with Pre Cast Chamber pit cover	JMV/VNT/Standard	Set	10
11	Lightning Arresters	Level III with 107 m radius With 5m Mast Height with 17.2 mm dia and 3 meter long CU Bonded Earthing Electrode, 1 set with 2 Electrode	Onay Plus	Set	2
12	Module mounting Structure	FIX TILT 10 DEG STRUCTURE BALLAST TYPE	Standard	kWp	2737.8
		80x60 mm Cable Tray	Standard	Meter	25
13	AC Cable Tray Ladder Type	320x60 mm Cable Tray	Standard	Meter	45
14	DC Cable Conduit	HDPE Conduit 1" Dia	Standard	Meter	200
14	De cable conduit	40x40 mm Cable Trav	Standard	Meter	360
	Do calda Tarra (Da characteria)	100x40 mm Cable Tray	Standard	Meter	145
15	DC Cable Tray (Perforated	200x40 mm Cable Tray	Standard	Meter	240
	Type with covery	250x40 mm Cable Tray	Standard	Meter	235
- 10		400x40 mm Cable Tray	Standard	Meter	330
16	MC4 Connector	254	Standard	Nos	580
18	Radiation Sensor	Pyranometer, Ambient Temperature & Module	Standard	NOS.	1
	Monitoring (PVDG not	Datalogger	Standard	NOS.	2
19	required)	RS 485 cable	Standard	Meter	270
ļ		HDPE Conduit 1" Dia., Schedule 40.	Standard	Meter	270
		1 " UPVC Pipe	Standard	Meter	610 510
-		0.75 Tap Valve	Standard	Nos	310
20	Module Cleaning System	1 to 0.75 inch reducer T	Standard	Nos.	35
		Flexible Rubber Pipe	Standard	Meter	60
		2 HP Motor	Standard	Nos.	2
21	Fire Protection	(4) 5kg sand bucket + (2) ABC type fire extinguishers		Set	4
22	Others	in Line Connectors (rin & King type iugs), insulators, Ferrules & Cable Tags, Silicon Sealant, Safety Tags, Electrical Tapes, PVC Clips, Anticorrosive Paste, Cable ties,		As	-
		Stainless Steel Screws, Nuts, Lugs, Bolts, Flexible Conduit			
This Bi	This Bill Of Material can be changed as per Site Condition				